

Lead in Water Testing Results  
South Washington County Schools  
Royal Oaks Elementary

On December 27<sup>th</sup>, 2018 Royal Oak Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Nurse's Office	SINK	2.2
Media Center Workroom	SINK	2.7
Resource Room	SINK	6.1
Gym A	FOUNTAIN	3.3
Gym B	FOUNTAIN	7.2
Hallway (outside gyms)	FOUNTAIN	2.7
Cafeteria	FOUNTAIN	1.6
Kitchen (1)	SINK	5.6
Kitchen (2)	SINK	4.9
Kitchen (3)	SINK	4.3
Kitchen (sprayer)	SPRAYER	4.9
Room 100 (left)	SINK	2.7
Room 100 (right)	SINK	1.8
Room 101	SINK	5.7
Room 101	FOUNTAIN	4.7
Room 102	SINK	5.2

Room 102	FOUNTAIN	3.5
Room 103	SINK	2.1
Room 103	FOUNTAIN	2.1
Room 104	SINK	5.3
Room 104	FOUNTAIN	4.9
Hallway (outside 104)	FOUNTAIN	3.9
Room 105	SINK	3.8
Room 105	FOUNTAIN	2.6
Room 106	SINK	3.5
Room 106	FOUNTAIN	1.9
Room 107	SINK	5.1
Room 107	FOUNTAIN	6.0
Room 108	SINK	5.6
Room 109	SINK	6.1
Room 109	FOUNTAIN	3.0
Room 110	SINK	4.3
Room 110	FOUNTAIN	3.5
Room 111	SINK	8.8
Room 112	SINK	4.4
Room 112	FOUNTAIN	6.1
Room 113	SINK	6.6
Room 113	FOUNTAIN	2.6
Staff Lounge	SINK	2.3
Room 201	FOUNTAIN	6.5
Room 202	SINK	2.4

Room 202	FOUNTAIN	9.12
Room 203	SINK	2.8
Room 203	FOUNTAIN	2.1
Room 204	SINK	4.8
Room 204	FOUNTAIN	2.3
Room 205	SINK	15.5
Room 206	SINK	3.3
Room 206	FOUNTAIN	1.8
Room 207	SINK	3.2
Room 207	FOUNTAIN	1.5
Room 208	SINK	4.9
Room 208	FOUNTAIN	3.0
Room 209	SINK	6.0
Room 209	FOUNTAIN	2.5
Room 210	SINK	6.7
Room 210	FOUNTAIN	4.2
Room 211	SINK	2.9
Room 211	FOUNTAIN	1.9
Room 212	SINK	6.2
Room 212	FOUNTAIN	2.6
Hallway (outside 212)	FOUNTAIN	2.4
Room 213	SINK	13.9
Room 214	SINK	14.7
Room 215	SINK	15.6
Room 216	SINK	12.4

**The following water source tested with results of the concentration to be over 20 parts-per-billion. The fixture of this water source was replaced, and a re-test was administered. Results of the initial test and retest are below. The water source re-tested under 20 parts-per-billion and no further action will be taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room 201	SINK	22.0	6.5